



NOTE: SEE SPECIFICATION SECTION 02210
FOR DESCRIPTION OF BACKFILL AND BEDDING
MATERIAL.

NOTES:

1. CAUTION MUST BE EXERCISED TO ENSURE PROPER PLACEMENT OF EMBEDMENT MATERIAL UNDER THE HAUNCHES OF THE PIPE.
2. POLYETHYLENE ENCASING ON ALL D.I. PIPE, FITTINGS, VALVES & APPURTENANCES.

	<p>REVISIONS</p>	<p>MISSOURI AMERICAN WATER STANDARD CIVIL TYPICAL INSTALLATION - D.I. PIPE IN SOIL DETAIL</p> <p>MISSOURI AMERICAN WATER ST. LOUIS, MO. 63141</p> <p>MISSOURI AMERICAN WATER ENGINEERING 727 CRAIG ROAD ST. LOUIS, MO. 63141</p> <p>DRAWN BY MEG PROJECT ENG'R APPROVED</p> <p>DATE 11-30-18 PROJECT IP</p> <p>USE DIMENSIONS ONLY SCALE N.T.S.</p> <p>USE APPROVED DRAWINGS ONLY FOR CONSTRUCTION PURPOSES</p> <p>0201-0601-SD55</p>
--	------------------	---